## TAMIL NADU FIRE - RESCUE SERVICES FIRE SERVICE LICENSE

(Under Section 13 of the Tamil Nadu Fire Service Act 1985 and with Tamil Nadu Service Rules 1990-Appendix-III)

S.L.No:-30/2024. L.Dis No:-761/B/2024.

Date: - 02.2024

License is hereby granted under Section 13 of the Tamil Nadu Fire Service Act 1985, for Running a College within the jurisdiction of Thuraiyur Taluk, S.F.No:- 314/12, 314/13, 314/14, 314/15 at the premises **M/s.NEHRU MEMORIAL COLLEGE**, Abinimangalam Village, Puthanampatti Post, Thuraiyur Taluk, Trichy District - 621007. Subject to the conditions noted thereon and other conditions as may be prescribed.

The above Premises Inspected By Station Officer (Transport) - Perambalur on: 08.02.2024.

## **CONDITIONS**

As per Col.13 of Appendix V to the Rules under section 13 of the Act

1. This License is valid for one year from the date of issue.

2. Installed fire and safety systems should be maintained as per NBC -2016 Part -4 fire safety code of practice.

3. The applicant will also get permission / No objection certificate from other department if necessary.

4. If the extension or alteration is made in the existing building and also for Changing of present business will also apply & get separate permission.

5. Regular License has to be obtained from competent authority.

6. All the fire extinguishers have to be recharged and maintained Periodically as per code of practice in IS: 2190/2010.

7. Advise to train the employee to operate the Fire Extinguisher.

- 8. If there is any deviation from the Govt.rules and act the license stand cancelled.
- 9. In compliance to section 3.2 of BIS 12459:1988 Code of practice for fire safety in cable regularization, a transparent fire retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the distribution box.

10. Hose reel system should be provided.

11. A Terrace tank with capacity of 10000 litres should be Provided.

12. A Terrace Pump with capacity of 450 lpm should be Provided.

(Office Seal with Date)

- 9 FEB 2024

District Officer
Fire and Rescue Service,
Perambalur District,

Perambalur.

To:- M/s.NEHRU MEMORIAL COLLEGE,

Abinimangalam Village, Puthanampatti Post, Thuraiyur Taluk, Trichy District. 621007.

p

Copy to: Deputy Director, Fire and Rescue Service, Central Region, Tiruchirappalli.